


- A. SHOP AREA 110 & EG LAB 112 SHALL BE CLASSIFIED AS A CLASS 1, DIV. 1 HAZARDOUS AREA IN ANY PITS OR DEPRESSIONS EXTENDING BELOW FINISHED FLOOR, AND AS CLASS 1, DIV. 2 FROM FINISHED FLOOR TO 18" AFF. ALL COMPONENTS SHALL MEET THE APPROPRIATE NEC REQUIREMENTS.
- B. ALL CONDUITS IN SHOP AREA 110 AND EG LAB 112 SHALL BE RGSC WITH THREADED FITTINGS.
- C. ALL FIRE ALARM AND EMERGENCY NOTIFICATION SYSTEM COMPONENTS SHALL BE INSTALLED IN ACCORDANCE WITH CLASS 1, DIV. 1 REQUIREMENTS REGARDLESS OF THE ELEVATION AT WHICH THEY ARE LOCATED.

1. MOUNT HORN STROBE HIGH ON WALL ABOVE FIRE DEPARTMENT WATER CONNECTION. COORDINATE MOUNTING HEIGHT WITH ARCHITECT.
2. HORN STROBE MUST OPERATE CONTINUOUSLY WHILE WATER FLOWS.



		100% SUBMITTAL		
REV	DATE	DESCRIPTION	CHECK	APP'D
DEPARTMENT OF TRANSPORTATION FEDERAL AVIATION ADMINISTRATION MIKE MONRONEY AERONAUTICAL CENTER – OKLAHOMA CITY, OKLAHOMA				
PSL – POWER SERVICES LABORATORY				
FIRE ALARM PLAN				
Construction Work Request No: 09-018745				
PREPARED BY Rees Associates			APPROVED BY Jon Berkman	
DRAWN	JDH	ISSUED BY OFFICE OF FACILITY MAINTENANCE AMP-400	DATE	May 26, 2011
	BLP		DRAWING NO.	E602
WORK ORDER NO.	09-018745		08-008257	22 OF 31

